Łukasiewicz Research Network – Institute of Ceramics and Building Materials
31-983 Krakow, Cementowa 8 Str., Poland
CENTER OF ADVANCED CERAMICS AND PREFABRICATION
phone: +48 22 889 48 51
www.icimb.lukasiewicz.gov.pl
info.warszawa@icimb.lukasiewicz.gov.pl
CERAMICS RESEARCH GROUP
phone: +48 601 362 348
agnieszka.ducka@icimb.lukasiewicz.gov.pl
Łukasiewicz Institute of Ceramics and Building Materials
AB 054

| Number of pages: 2 | **Test Report No 173/P/LB/2026(EN)** | | Page 1 |
|---|---|---|---|
| **ORDERER** | Integart Sp. z o.o., ul. Maszynowa 1, 55-330 Błonie | | |
| **CONTRACT/ ORDER NO** | 0L0000P6 | **CASE NO.** | WP.5212.171.2026.AD |

| | | |
|---|---|---|
| Subject of testing | Floor covering | Data based on the Client's declaration |
| Sample description | **LX Hausys Vizuon LM40000overlaminate** | |
| Producer | LX Hausys Ltd., 98, Huam-ro, Jung-gu, 04637 Seoul, Korea | |
| Sample taken by | Orderer | |
| Samples delivered by | Courier | |
| Designation of sample | 139P/2026 | |
| Number of sample | 1 piece 58x122 cm | |
| Date of receipt the samples | 22.09.2026 | |
| Date of tests | 06.10-07.10.2026 | |

**TEST METHODS/PROCEDURES**:

EN 16165:2021-10 Determination of slip resistance of pedestrian surfaces - Methods of evaluation. Annex B Shod ramp test
DIN EN 16165:2023-02 Determination of slip resistance of pedestrian surfaces - Methods of evaluation. Annex NB Assessment classes

## RESULTS OF TESTS

1. Determination of slip angle.

Sample size: 0,5 $m^2$

| | |
|---|---|
| Ramp test value $a_{shod}$[°] | 6,2 |

Classification:

| | |
|---|---|
| Anti-slip properties class | R 9 |

| Number of pages: 2 | **Test Report No 173/P/LB/2026(EN)** | Page 2 |
|---|---|---|

**COMMENTS:**

1. The given results uncertainty values are the expanded uncertainty calculated for a confidence level of approximately 95% and a coverage factor k=2 and do not take into account the sampling stage.
2. Results of tests relate exclusively to tested objects.
3. Test report may be copied only as a whole, whereas for partial coping the consent of laboratory is required.

Warsaw, 14.10.2026

| PREPARED BY | AUTHORIZED BY |
|---|---|
| A. Ducka | Z-ca Lidera Grupy Badawczej Ceramika<br>Ducka<br>mgr Agnieszka Ducka |

THE END