

Number	17-003565-PR01 (NW-H05-05-en-01)
Owner	Avery Dennison Europe Holding (Deutschland) GmbH & Co. KG In der Graslake 41-49 58332 Schwelm Germany
Product	Laminated safety glass (LSG)
Designation	Shipping name: SF Clear 7 mil i
Details	Overall dimensions (W x H) 876 mm x 1938 mm; Glass configuration Float 4 mm / PET film 177.8 µm; Thickness 4.08 mm
Special features	One-sided laminated glass pane
Result	

Classification Pendulum Test according EN 12600



**Class: 2 - (B) - 2**

#### Basis \*)

EN 12600:2002-11

\*) and corresponding national versions  
e.g. DIN EN)

Test report: 17-003565-PR01 PB-H05-05-de-01

#### Representation



#### Instructions for use

The results obtained can be used as evidence in accordance with the above basis.

#### Validity

There is no time limit.

When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

The data and detailed results given relate solely to the tested/described specimen.

This test does not allow any statement to be made on further characteristics of the present structure regarding performance and quality, in particular the effects of weathering and ageing. The classification will be valid as long as the product remains unchanged and the above bases have not changed.

#### Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

#### Identity-Check



[www.ift-rosenheim.de/ift-geprueft](http://www.ift-rosenheim.de/ift-geprueft)  
ID: BB1-EBF3D

ift Rosenheim

09.03.2018



Konrad Querengässer, Dipl.-Ing. (FH)  
Head of Testing Department  
Security/Safety Testing



Stefan Hehn, Dipl.-Ing. (FH)  
Operating Testing Officer  
Material Testing