



Avenue Gouverneur Cornez, 4
B-7000 MONS (Belgium)
Tel. (065)40.34.34
Fax (065)34.80.05

V.A.T. : BE 0413.106.271
RC MONS : 130.828 - Registration : 08/02/01

<http://www.bcrc.be/>

TEST REPORT : N° 2018B SEC 34390-2

Including 3 pages
Page 1/3

Mons, May 15th, 2018

REQUESTED BY : **AVERY DENNISON MATERIALS BELGIUM**
Bld J Fitzgerald Kennedy
7060 SOIGNIES
BELGIUM

REFERENCE OF THE REQUESTED : PO 358049

CONCERNED MANUFACTURER: **AVERY DENNISON ISRAEL LTD**
Kibbutz Hanita,
2288500, Israel

NUMBER OF SAMPLES AND IDENTIFICATION : **SF Clear 7 Mil X - see page 2**

PURPOSE OF THE REQUEST : **TEST ON SAFETY GLASS IN COMPLIANCE WITH THE REQUIREMENTS OF THE STANDARD EN 12600:2003 (PENDULAR TEST)***

SAMPLES RECEIVED ON : 26/04/2018

TESTING DATE : 09/05/2018

COMMENTS : * Test and/or sampling under accreditation

 **Notified body (Id.N°1174)**
according to Regulation (EU) No 305/2011 - Construction products

TEST ON SAFETY GLASS IN COMPLIANCE WITH
THE REQUIREMENTS OF THE STANDARD EN 12600 (2003)*

Tested side : Film

On 12 samples

Dimension : 876*1938 mm


Testing date : 09/05/2018

Temperature in the test room: 20,4°C

Test piece number	Actual thickness (mm)	Drop height (mm)	Inspection of the test piece after impact
1	4.09	190	Broken in compliance with the §4.a
2	4.10	190	Broken in compliance with the §4.a
3	4.09	190	Broken in compliance with the §4.a
4	4.09	190	Broken in compliance with the §4.a
5	4.05	450	Broken in compliance with the §4.a
6	4.09	450	Broken in compliance with the §4.a
7	4.04	450	Broken in compliance with the §4.a
8	4.05	450	Broken in compliance with the §4.a
9	4.05	1200	Broken in compliance with the §4.a
10	4.07	1200	Broken in compliance with the §4.a
11	4.06	1200	Broken in compliance with the §4.a
12	4.05	1200	Broken in compliance with the §4.a

Conclusion

The tests carried out on the samples considered in this report gave results **in compliance** with the requirements of the EN 12600 (pendulum test) standard for the safety **Classification 1B1**.



D. LIBERT
Head of Department
Glazing and Components - INISMa